

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 18/07/2026

It is certified that an inspection team headed by Sri. V. Raja Rao, Senior Water Analyst

(Name of Officers with designation) from Regional public Health Lab, Guntur

inspected the ST. Joseph's High School, Peddakakani, Guntur Dt.

(Name & Address of the school) on 10/07/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 4740, 4741 dated 10/07/2026.

of Regional public Health Laboratory (PHED Lab) certified that

the ST. Joseph's High School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till One year.

Signature with Seal:

Name

Designation

Name & Address of the Office / Department

V. RAJA RAO
Senior Water Analyst
Regional
Lab. Guntur

To ST. Joseph's High school

Pedda kakani
(Name & Address of the Institution)

Guntur District A.P.

Senior Analyst (Water)
Regional Laboratory
Medical College Campus
Guntur-4.

Note: The certificate is to be issued by authorized officers of PHED Lab / local bodies



GOVERNMENT OF ANDHRAPRADESH
DIRECTORATE OF I.P.M.PH.LABS, FOOD (H) ADMN, Mangalagiri, Guntur.
REGIONAL PUBLIC HEALTH LABORATORY, GUNTUR

REPORT OF PHYSICO CHEMICAL ANALYSIS OF WATER

Sample from	ST.Joseph'S High School, Peddakakani, Guntur Dt.	Lab. Ref. No:	4740
		Collected on	10.07.2026
		Received on	10.07.2026
Collected by	Staff.	Source Profile	Ro Water

		Source / Sample	Limits as per IS 10500:2012	
		Drinking water tap Ro at above address.		
S. No	Parameter		Desirable (Acceptable limit)	Permissib le limit in the absence of alternativ e source
Physical Parameters				
1	Colour (Hazen units)	<5.0	5	15
2	Turbidity in NTUS``	0.1	1	5
3	Odour	Unobjectionable	Unobjectionable	Agreeabl e
4	pH	6.9	6.5 – 8.5	No relaxation
5	Conductivity at 25 °C (Micro Mhos/ Cm)	110	...	
6	TDS (mg/L)	72	500	2,000
Chemical parameters (mg/L)				
1	Alkalinity (as CaCO ₃)	Nil	...	
2	Total Alkalinity. Max	20	200	600
3	Total hardness max	24	300	600
4	Calcium hardness (as CaCO ₃)	12	..	
5	Magnesium hardness (as CaCO ₃)	12	..	
6	Calcium (as Ca)	5.0	75	200
7	Magnesium (as Mg)	3.0	30	100
8	Ammonical Nitrogen	Nil	...	
9	Nitrite (as N)	Nil	...	
10	Chloride (as Cl)	24	250	1,000
11	Fluoride (as F)	0.1	1	1.5
12	Iron (as Fe)	Nil	0.3	No relaxation

Remarks: The given sample physico chemically Satisfactory for drinking purpose as the analysed parameters are within the desirable limits.



[Handwritten Signature]
 Senior Analyst (Water)
 Regional Laboratory
 Medical College Campus
 Guntur-4.

GOVERNMENT OF ANDHRA PRADESH
DIRECTORATE OF I.P.M., P.H.LABS, FOOD (H), ADMINISTRATION, Mangalagiri, Guntur
REGIONAL P.H.LABORATORY, MEDICAL COLLEGE CAMPUS, GUNTUR -4
REPORT OF MICROBIOLOGICAL ANALYSIS OF WATER

Sample(s) from: ST.Joseph'S High School,Peddakakani,Guntur Dt.

Collected on: 10.07.2026

Received on : 10.07.2026

Paid / Free : paid

Collected by : Self.

S.No	Lab Ref. No	SOURCE	Residual Chlorine mg.per litre	MPN of Coliform Bacteria Per 100 ml.	Nature of Coliform Bacteria Isolated	MP N of Esch coli.
1	4741	Drinking water tap Ro at above address.	Nil	Nil	-	-

Remarks:- The given sample is bacteriologically Satisfactory for drinking purpose as evidenced by the Nil MPN count of coliform bacteria.



[Signature]
Senior Analyst* (Water)
Regional Laboratory
Medical College Campus
Guntur-4.